

# Preliminary Assessment Report

## Project 6554691, 9029 16TH AVE SW

---

**Assessment Completed:** 9/30/2016

**Project Description:** Demolish existing multifamily building on site; construct 4-story multi-family building, 1st floor 1844 sf of retail, 2nd-4th floor to be totally 8 units.

**Primary Applicant:** [Qi Qi](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

### Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Seattle Department of Construction and Inspections (SDCI) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with SDCI. **Please bring a copy of this report to your intake appointment.**

### Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

#### SDCI Drainage Requirements

Eric Dripps, (206) 727-3676, [Eric.Dripps@seattle.gov](mailto:Eric.Dripps@seattle.gov)

#### SDCI Land Use Requirements

Onum Abbey Esonu, (206) 233-7196, [Onum.Esonu@Seattle.Gov](mailto:Onum.Esonu@Seattle.Gov)

#### SDCI Preapplication Site Visit Requirements

Joe Eckhoff, (206) 233-5034, [joe.eckhoff@seattle.gov](mailto:joe.eckhoff@seattle.gov)

#### Seattle City Light Requirements

Ray Ramos, (206) 615-1193, [ray.ramos@seattle.gov](mailto:ray.ramos@seattle.gov)

#### Seattle Department of Transportation Requirements

Emily Ehlers, (206) 518-4608, [Emily.Ehlers@seattle.gov](mailto:Emily.Ehlers@seattle.gov)

#### Seattle Public Utilities Requirements

Steve Resnick, (206) 233-7234, [ResnicS@seattle.gov](mailto:ResnicS@seattle.gov)

#### Water Availability

SPU Staff, (206) 684-3333, [SPUWaterAvailability@Seattle.Gov](mailto:SPUWaterAvailability@Seattle.Gov)

## Other Resources

- General questions about the permit process: Contact the SDCI Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [SDCI](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

## Requirements

### **SDCI Drainage Requirements**

The following requirements are based on the current stormwater and side sewer codes.

**\*\*The new 2016 Stormwater Code becomes effective on January 1, 2016. Projects with an accepted application (successful SDCI permit intake) date after December 31, 2015 will be reviewed under the new code. The drainage requirements indicated below are based on the 2016 Stormwater Code. If your project will be submitted prior to January 1, 2016, please contact the SDCI Drainage Reviewer to determine drainage requirements.\*\***

#### **Existing Public Drainage Infrastructure**

Combined sewer main location: **16th Ave SW**

Combined sewer main size: **10-inch**

#### **Drainage**

Infiltration Investigation Required: **Yes**

Projects that require On-site Stormwater Management, Flow Control, and/or Water Quality Treatment must first investigate infiltration feasibility before selecting other BMP's. See Seattle Stormwater Manual, Volume 3, Section 3.2 and Appendix D. If feasible, infiltration testing per the requirements in Appendix D is required prior to application. Submit a completed Infiltration Checklist with the construction permit application. Checklists are available on the DPD Stormwater Code website.

<http://www.seattle.gov/dpd/codesrules/codes/stormwater/default.htm>

Please note: projects that infiltrate 5,000 square feet or more of hard surface area must conduct Groundwater Monitoring for a full wet season or one full year if infiltrating 10,000 square feet or more of hard surface area. See Table 3.1 in Section 3.2.

#### **Project Type and Drainage Basin**

The storm drainage point of discharge (SMC 22.805.020) is located at: **Combined sewer**

Project Type: **Parcel-based**

Drainage Basin: **Public combined sewer**

#### **Drainage Control Compliance**

Drainage Review Required: **Yes**

Drainage Control Review is required for this project per SMC 22.807.020. Submit a completed **Standard Construction Stormwater Control and Post Construction Soil Management (CSC/SOIL) Plan** and a completed **Standard Drainage and Wastewater Control (DWC) Plan** including the **Site and Drainage Control Summary** from [On-site Stormwater Management Calculator](#).

Note: For projects with 5,000 square feet or more of new plus replaced hard surface, a comprehensive drainage control plan, construction stormwater control plan, soil amendment plan, and drainage report shall be prepared by a licensed engineer.

Soil Amendment Required: **Yes**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water

quality per SMC 22.805.030.A, 22.805.040.A, or 22.805.050.A. Complete the **Post Construction Soil Management Plan** on the [Standard CSC/SOIL Plan](#).

On-site Stormwater Management Required: **Yes**

Parcel-based projects with 7,000 square feet or more of land disturbing activity, 1,500 square feet or more of new plus replaced hard surface or, if on a lot or parcel created or reduced in size on or after January 1, 2016, 750 square feet or more of new plus replaced hard surface, must implement **On-site Stormwater Management** (infiltration, dispersion, bioretention, green roofs, permeable pavement, rainwater harvesting, etc.) to manage runoff from all hard surfaces on-site per SMC 22.805.050.B. and Director's Rule 21-2015.

Submit an [On-site Stormwater Management Calculator](#) and show the On-site Stormwater Management BMP's and surface designation on the [Standard Drainage and Wastewater Control Plan](#).

Flow Control Required: **No**

Based on the information provided, adherence to Flow Control Standards is not required for this project.

### **Water Quality**

No requirements

### **Wastewater**

The wastewater point of discharge (SMC 21.16.070.B) is located at **Public Combined Sewer**.

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

### **Permanent and Temporary Dewatering**

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following: **Combined system**.

### **Side Sewer**

The existing side sewer for a new or converted building or dwelling unit may be reused pursuant to SMC 21.16.240. If there is an increase of dwelling units or buildings the [Side Sewer Evaluation and Certification Form](#) must be completed by a licensed engineer.

For your information:

In serving establishments (i.e restaurants, cafes, lunch counters, cafeterias, bars and clubs, hotels, hospitals, sanitariums, factory or school kitchens, or other establishments where grease is introduced into the drainage or sewage system), there may be additional requirements to control the discharge of fats, oils, and grease (FOG) into the sanitary sewer system.

Please contact: [Gary.Christiansen@seattle.gov](mailto:Gary.Christiansen@seattle.gov) in SPU's FOG Program to determine pretreatment requirements to protect the municipal sewer system from FOG generated by food preparation and handling.

Any internal plumbing modifications require a plumbing permit from King County Public Health 206-684-5198.

For more information, visit:

<http://www.seattle.gov/util/MyServices/DrainageSewer/FatsOilsGrease/index.htm>

<http://www.kingcounty.gov/healthservices/health/ehs/foodsafety/FoodBusiness.aspx>

## **SDCI Land Use Code Requirements**

### **Street Requirements**

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/row/manual/manual/>). Show required street improvements on your "enhanced site plan" at SDCI permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to SDCI permit application intake.

## 16TH AVE SW

Street trees shall be provided in the planting strip according to Seattle Department of Transportation Tree Planting Standards. Contact SDOT Urban Forestry (for residential projects: (206) 684-TREE; for all others: (206) 684-5693), to determine species of tree and standards of planting. Please add a note to the site plan showing size, location and species of tree to be planted.  
<http://www.seattle.gov/transportation/treeplanting.htm>.

Landscaping is required to be installed in the planting strip. Contact SDOT Urban Forestry to determine species of landscaping and standards of planting. For residential projects, call (206) 684-TREE; for all others, call (206) 684-5693. Please add a note to the site plan showing size, location and species of shrubs and groundcover to be planted.

## Land Use

An arborist report may be required. See CAM 242 for more detail.

## Other Requirements

A presubmittal conference is required before submitting an application. Details for preparing and submitting a presubmittal request form can be found at our Web site  
([http://www.seattle.gov/dpd/Publications/Forms/Building\\_Permit/default.asp](http://www.seattle.gov/dpd/Publications/Forms/Building_Permit/default.asp)).

## Pre-Application Site Visit (PASV) Requirements

PASV report requirements may be subject to additions, changes, or modifications by the department. The purpose of the report is to alert the applicant that there may be unusual or complex site conditions that trigger requirements from the department regarding this project. **The applicant is responsible for providing all required documents at the intake appointment.** If you have questions about this report or the PASV process, please contact the SDCI Site Development Team at (206) 684-8860.

**Note:** Any project application associated with the development site can utilize the results from this PASV if the application is accepted by SDCI within 24 months of the above inspection date. After 24 months, the applicant must apply for another PASV. No extensions will be granted.

The site plan did not include the following existing or proposed elements:

Site plan does not show 2' elevation contours.

## ECA Mapping Unit and Type

Non-ECA

## Earth Disturbance

Please show all existing and proposed retaining walls/rockeries and the exposed height.

## Existing ROW Conditions

### 16TH AVE SW

Street conditions:

Concrete paving

Asphalt paving

Visible pavement width is: 44 FT.

Curb conditions:

Curb adjacent to site

Concrete

Approximate curb height: 5 inches

A storm inlet is located <350 ft from the site and prior to crossing a public right of way. Road surface is crowned. CBs located along curblin e near SW Barton.

It appears that drainage from that discharge point will remain in the gutter line all the way to the nearest inlet structure, but this assessment is preliminary and it is the responsibility of the applicant to meet all relevant SW code requirements.

## Alley to West

Gravel surface

Comments: Alley is ~12 Ft wide. There appears to be a low point just south of the site.

## Potential Impacts to Seattle Parks Property

No parks property in vicinity

## Tree Protection

Trees greater than 6 inches in diameter as measured 4.5 ft above ground are present on the site but not shown on the site plan. Show the dripline of

- 1) **all** trees on the site,
- 2) adjacent trees that encroach on the site that are greater than 6 inches in diameter as measured 4.5 ft above ground, and
- 3) **all** trees located in the adjacent ROW.

Include common and scientific names for all trees shown. For more information, see [Director's Rule 16-2008](#) and [Tip 242](#).

## Construction Stormwater Control

All projects with earth disturbance, regardless of size, require temporary and permanent stormwater control in accordance with the Construction Stormwater Control (CSC) Technical Requirements Manual ([DR 21-2015, Volume 2](#)).

**Show the following on the [Construction Stormwater Control and Soil Amendment Standard Plan](#):**

Place compost socks, compost berms, filter fabric fencing, straw bales, straw wattles, or other approved perimeter control BMPs to eliminate construction stormwater runoff.

Show the location of a stabilized construction access to the site; show methods to eliminate uncontrolled conveyance of mud and dirt into the right of way (ROW).

Place silt-trapping inserts in receiving catch basins located within 10 feet of construction entrance.

Cover bare soil with compost blankets, straw, mulch, matting, or other approved equal to control construction stormwater runoff.

Cover stockpiles and bare slopes with compost blankets, tarps, matting or other approved equal to control construction stormwater runoff.

A First Ground Disturbance inspection is required before any ground disturbance related to this permit, including demolition, tree cutting, clearing, grubbing, and grading. After your permit is issued, schedule an inspection by calling (206) 684-8900 or [online](#) at <http://web1.seattle.gov/DPD/InspectionRequest/default.aspx>.

## Inspectors Notes

No additional inspection notes available.

## Seattle City Light Requirements

### Street/Alley Requirements

#### 16TH AVE SW

Clearance from Structures: Fourteen (14) feet radial clearance is required between power lines and any part of the permanent structure per Seattle City Light Construction Standard D2-3 (<http://www.seattle.gov/light/engstd/docs2/d2-3.pdf>). Transmission lines require greater clearance. Changes to SCL's system to meet clearances are done at the project's expense. There are overhead high voltage lines along 16th Ave SW,

Working Clearance: State law requires construction workers, their tools, machinery, equipment, and materials to maintain a 10-foot clearance from power lines. Review WAC 296-24-960 and OSHA 1910.333(c)(3)(i). Transmission lines require greater clearance. To work near power lines, notify SCL well in advance to de-energize and ground the lines, or relocate the lines temporarily. This City Light work is done at the project's expense. City Light may not be able to grant customer requests to temporarily relocate or de-energize the distribution system. There are overhead high voltage lines along 16th Ave SW,

An SCL engineer will require scaled building elevation drawings to determine clearances. Please submit an extra set of plans at DPD intake.

Based on our assessment of the size of your project, you may need transformers on your private property for power service to your building. This can be done with vaults inside the building, below-grade vaults, or above-grade pads exterior to the building. Include these facilities for your project power needs in your building plans. SCL has access, clearance, size and location requirements for vaults. Some transformers require long lead times to obtain. Contact SCL well in advance to provide electrical service size and voltage details.

## Conservation

Built Smart Programs - SCL offers developers of 5+ unit multifamily buildings incentives for installation of energy efficiency measures. From insulation and windows to lighting and appliances, take advantage of new technologies and construct a more efficient building with our help. For more information: contact Phoebe Warren at (206)684-3795 or [phoebe.warren@seattle.gov](mailto:phoebe.warren@seattle.gov).

## **Notes to Applicant**

For new service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Tom Gravell, 206-386-1672, [thomas.gravell@seattle.gov](mailto:thomas.gravell@seattle.gov). Be advised that it is the applicant's responsibility to seek guidance from City Light. Failure to contact City Light early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

## **SDOT Requirements**

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: [http://www.seattle.gov/transportation/stuse\\_docs.htm](http://www.seattle.gov/transportation/stuse_docs.htm). Whenever possible, specific reference notation for these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

### **SDOT Permitting Information**

Initial Review Deposit: To be determined

SDOT Plan Requirements: Plan

SDOT Permit Requirements: Group 1:Over-the-Counter. Obtain from SDOT anytime prior to construction in the right of way.

Based on the scope of your project and the proximity to the lot line a SIP may be triggered by the extent of construction impacts to existing street, sidewalk or alley improvements. If more than 2,000 sf of impervious surface in the right of way will be replaced a SIP will be required.

### **Street Improvement Requirements**

#### **16TH AVE SW**

Street trees shall be provided in a 5'-wide (minimum) planting strip, located between the sidewalk and the curb. Per SMC 15.43.040, private property owners are responsible for the planting and maintenance of street trees in accordance with Standard Plan 100 and SDOT's Street Tree Manual. Refer to the Right-of-Way Improvements Manual (ROWIM) 4.14 for design criteria. Provide Lavelle Hawthorn 18' o/c

New/replacement sidewalk: See Seattle Right of Way Improvements Manual (ROWIM) as well as the City of Seattle Standard Plan 420, 421 and 422. Provide 6' sidewalk.

### **Alley Requirements**

#### **Alley to West**

Provide all vehicle access to the site via the alley.

Provide trash collection via the alley. Coordinate with SPU.

### **Discretionary ROW Improvements**

Other requirements: Site is located along a designated safe walking route to neighborhood schools. Site located along an existing bicycle facility.

## **SPU Requirements**

### **Water Availability**

Your water availability assessment has been approved.

Water Availability Certificate reference number: 20161123

Water Availability Certificate status: Approved with No Changes

Prepared by: Kerry Murdock

### **Existing Water System Information**

Proximity of nearest fire hydrant is: 166 feet E of property. Meets standards.

Water Main:

Size: 8 inches

Material: Cast Iron

Class: B

- Standard

- Abutting

Water Main is available to serve in: 16th Avenue SW

Distance of main to W margin of street is 29 feet.

Public ROW width is 69 feet.

Water Service(s):

Size: 3/4"

Material: Plastic

For all multifamily, commercial, and industrial properties, the requirements for solid waste storage and pickup are outlined in SPU CAM 1301, available on the web at:

[http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos\\_004542.pdf](http://www.seattle.gov/util/stellent/groups/public/@spu/@csb/documents/webcontent/cos_004542.pdf). For questions about solid waste requirements, contact Liz Kain, (206) 684-4166, [Liz.Kain@seattle.gov](mailto:Liz.Kain@seattle.gov).

## **Other Requirements**

## **Other Requirements**

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to SDCI Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or [www.seattle.gov/neighborhoods/preservation](http://www.seattle.gov/neighborhoods/preservation) to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your SDCI intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our SDCI intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, [Michale.Crooks@seattle.gov](mailto:Michale.Crooks@seattle.gov), or visit the [Licensing and Tax Administration Division website](#).